

## EAGLE LAKE TEXAS WATER LEVEL POLICY

The “Eagle Lake Texas Association” Board authorized a survey of the water level of Eagle Lake. This survey was conducted by Prein&Newhof, Engineers & Surveyors on May 29, 2008. The purpose of the survey was to establish an “Ordinary High Water Mark” (OHWM) for Eagle Lake which will be used to govern the operation of the pump in the boards attempt to maintain an appropriate and healthy lake level.

The following elevation measurements were provided on May 29, 2008:

- “Ordinary High Water Mark” (OHWM) 899.84 Elevation

## EAGLE LAKE PUMP OPERATION POLICY

The following policy shall determine yearly lake pump operation at Eagle Lake:

- During the months of October, November, December, January, February and March; the pump will be disconnected from power and not operational.
- During the months of April, May, June, July, August and September; the pump will only run as necessary to assist in keeping the lake level between a range of 8 to 4 inches below the Official High Water Mark.
- Whenever the water level reaches 4 inches or higher, below the Official High Water Mark, the pump will be off and not operational.

ELTA Board Approval: 2012